PANDA Solenoid Design Progress

Andrea Bersani INFN Sezione di Genova



Cryogenic chimney design Including requested modifications



- Cool down scenarios
 - Procedure definition and time estimation



- Cool down scenarios
 - Procedure definition and time estimation
- Cable joints loss
 - Cable welding technique choice



- Cool down scenarios
 - Procedure definition and time estimation
- Cable joints loss
 - Cable welding technique choice
- New thermal simulations
 - Comparison between different codes



- Cool down scenarios
 - Procedure definition and time estimation
- Cable joints loss
 - Cable welding technique choice
- New thermal simulations
 - Comparison between different codes
- Open questionsYes, we have





The Cryogenic Chimney



The Cryogenic Chimney



The Cryogenic Chimney



The flanges for two
 turbo pumps are
 foreseen

The design is based on BaBar and Atlas ones

The Control Dewar Manual valve Current leads Control valves Cryogenic Bayonets LHe coax Feed LHe Reservoir Current leads (~25 l) Reservoirs (~5l) GSI, 8 Dec. 2009 (Holiday)

Possible providers has been identified and realistic components are included in the model



Possible providers has been identified and realistic components are included in the model

The current leads are AMI 5KA commercial counterflow current leads



Possible providers has been identified and realistic components are included in the model

- The current leads are AMI 5KA commercial counterflow current leads
- The control valves, manual valve and cryogenic bayonets are from Cryocomp



Possible providers has been identified and realistic components are included in the model

- The current leads are AMI 5KA commercial counterflow current leads
- The control valves, manual valve and cryogenic bayonets are from Cryocomp
- In the cut out the the super-insulation is not shown, anyhow the space for it is foreseen



Possible providers has been identified and realistic components are included in the model

- The current leads are AMI 5KA commercial counterflow current leads
- The control valves, manual valve and cryogenic bayonets are from Cryocomp
- In the cut out the the super-insulation is not shown, anyhow the space for it is foreseen
- Stimation of the total cryogenic losses confirmed the reference values quoted in the TDR

An increase of the Cryogenic Chimney length has been requested in two times

An increase of the Cryogenic Chimney length has been requested in two times

The distance between the cryostat and the control Dewar has been increased by 550 mm



An increase of the Cryogenic Chimney length has been requested in two times

- The distance between the cryostat and the control Dewar has been increased by 550 mm
- This should allow safe operations for the upstream doors and allow all the needed clearance for the upper support beams



An increase of the Cryogenic Chimney length has been requested in two times

The distance between the cryostat and the control Dewar has been increased by 550 mm

This should allow safe operations for the upstream doors and allow all the needed clearance for the upper support beams

At the moment, all the conflicts have been removed and the cryostat model fits the yoke model as it is in the WIKI



PANDA TS Overview



Panda Coil Keep away zone



Panda Coil Keep away zone



Panda Coil Keep away zone



A modification in the design of the lower part of the chimney has been requested by the DIRC people



A modification in the design of the lower part of the chimney has been requested by the DIRC people

The design of the flange has been radically modified to allow more space for the DIRC readout electronics





A modification in the design of the lower part of the chimney has been requested by the DIRC people

The design of the flange has been radically modified to allow more space for the DIRC readout electronics

The new version fits the previous requirements



- A modification in the design of the lower part of the chimney has been requested by the DIRC people
- The design of the flange has been radically modified to allow more space for the DIRC readout electronics
- The new version fits the previous requirements
- The feasibility has been checked with INFN Genova mechanical workshop



- A modification in the design of the lower part of the chimney has been requested by the DIRC people
- The design of the flange has been radically modified to allow more space for the DIRC readout electronics
- The new version fits the previous requirements
- The feasibility has been checked with INFN Genova mechanical workshop
- This change, anyhow, reflects in a possible cost and time increase







The two busbars
 are obtained by three
 SC cables welded
 together





The two busbars
 are obtained by three
 SC cables welded
 together

The four pipes
bring LHe and cold
helium gas





- The two busbars are obtained by three SC cables welded together
- The four pipes
 bring LHe and cold
 helium gas
- The modification
 was needed to allow
 this small cut in the
 edge




An estimation of the cool-down time has been done



 An estimation of the cool-down time has been done
 These estimations are based on "reasonable" assumptions

- An estimation of the cool-down time has been done
 These estimations are based on "reasonable" assumptions
- The refrigerator foreseen for the PANDA solenoid is rated for 100 l/h of LHe or 280 W @ 4.5 K



- An estimation of the cool-down time has been done
 These estimations are based on "reasonable" assumptions
- The refrigerator foreseen for the PANDA solenoid is rated for 100 l/h of LHe or 280 W @ 4.5 K
- We want to avoid large temperature difference in the cold mass (to avoid thermal stresses)



- An estimation of the cool-down time has been done
 These estimations are based on "reasonable" assumptions
- The refrigerator foreseen for the PANDA solenoid is rated for 100 l/h of LHe or 280 W @ 4.5 K
- We want to avoid large temperature difference in the cold mass (to avoid thermal stresses)
- We must cope with the cooling circuit impedance



- An estimation of the cool-down time has been done
 These estimations are based on "reasonable" assumptions
- The refrigerator foreseen for the PANDA solenoid is rated for 100 l/h of LHe or 280 W @ 4.5 K
- We want to avoid large temperature difference in the cold mass (to avoid thermal stresses)
- We must cope with the cooling circuit impedance
- The cold mass is ~ 4.2 t, the enthalpy variation between 300 and 4.5 K is 2.3.10⁸ J



The minimum theoretical cool-down time can be evaluated assuming to circulate all the produced LHe in the cooling circuit, 3.5 g/s at 4.5 K, and recovering it as a gas at 300 K



The minimum theoretical cool-down time can be evaluated assuming to circulate all the produced LHe in the cooling circuit, 3.5 g/s at 4.5 K, and recovering it as a gas at 300 K

All the enthalpy is transferred from the cold mass to the coolant (perfect thermal exchange regime)



The minimum theoretical cool-down time can be evaluated assuming to circulate all the produced LHe in the cooling circuit, 3.5 g/s at 4.5 K, and recovering it as a gas at 300 K

All the enthalpy is transferred from the cold mass to the coolant (perfect thermal exchange regime)

With these assumptions, the cool-down time is of the order of <u>12 hours</u>



The minimum theoretical cool-down time can be evaluated assuming to circulate all the produced LHe in the cooling circuit, 3.5 g/s at 4.5 K, and recovering it as a gas at 300 K

All the enthalpy is transferred from the cold mass to the coolant (perfect thermal exchange regime)

With these assumptions, the cool-down time is of the order of <u>12 hours</u>

Mowever, this scenario is unrealistic, due to pressure and temperature gradients considerations



A more realistic scenario is to cool down the coil using a mixture of liquid Helium and warm gas (300 K from in the control dewar using the CV3 cold valve to keep the temperature difference between the input and output of the coil below 50 K)



A more realistic scenario is to cool down the coil using a mixture of liquid Helium and warm gas (300 K from in the control dewar using the CV3 cold valve to keep the temperature difference between the input and output of the coil below 50 K)

The second assumption is to use a constant flow of coolant of 0.5 g/sec (10Nm³/h STP) to account for the hydraulic impedance of the cooling loops



A more realistic scenario is to cool down the coil using a mixture of liquid Helium and warm gas (300 K from in the control dewar using the CV3 cold valve to keep the temperature difference between the input and output of the coil below 50 K)

The second assumption is to use a constant flow of coolant of 0.5 g/sec (10Nm³/h STP) to account for the hydraulic impedance of the cooling loops

The second assumption is a quite conservative guess



A more realistic scenario is to cool down the coil using a mixture of liquid Helium and warm gas (300 K from in the control dewar using the CV3 cold valve to keep the temperature difference between the input and output of the coil below 50 K)

The second assumption is to use a constant flow of coolant of 0.5 g/sec (10Nm³/h STP) to account for the hydraulic impedance of the cooling loops

- The second assumption is a quite conservative guess
- The realistic cool-down time is <u>~8 days</u>





Tuesday, March 9, 2010



The resistance of the cable joints has been evaluated in a 3D finite element model



The resistance of the cable joints has been evaluated in a 3D finite element model

It is foreseen to weld the two ends of cable pieces welding the aluminium matrix with the TIG technique



The resistance of the cable joints has been evaluated in a 3D finite element model

It is foreseen to weld the two ends of cable pieces welding the aluminium matrix with the TIG technique

 \ast From the voltage drop map the resistance has been calculated to be ~ 5.10^{-11} \Omega







The heat input per joint has been evaluated to be approximately 1.25 mW





The heat input per joint has been evaluated to be approximately 1.25 mW

This is negligible w.r.t. the radiation heat load in a section between two cooling pipes, evaluated in 150 mW





The heat input per joint has been evaluated to be approximately 1.25 mW

This is negligible w.r.t. the radiation heat load in a section between two cooling pipes, evaluated in 150 mW

It is negligible w.r.t. the conduction heat load due to the axial supports, evaluated to be 140 mW





- The heat input per joint has been evaluated to be approximately 1.25 mW
- This is negligible w.r.t. the radiation heat load in a section between two cooling pipes, evaluated in 150 mW
- It is negligible w.r.t. the conduction heat load due to the axial supports, evaluated to be 140 mW
- The effect on the temperature map of the joint is not appreciable in the FE calculation







Following the increasing detail in the cold mass design, a new set of FE thermal calculations have been performed



Following the increasing detail in the cold mass design, a new set of FE thermal calculations have been performed

Comsol MultiPhysics code has been used in addition to ePhysics to make a comparison possible



Following the increasing detail in the cold mass design, a new set of FE thermal calculations have been performed

Comsol MultiPhysics code has been used in addition to ePhysics to make a comparison possible

All the results are in fair agreement with the numbers quoted in the TDR



Following the increasing detail in the cold mass design, a new set of FE thermal calculations have been performed

Comsol MultiPhysics code has been used in addition to ePhysics to make a comparison possible

All the results are in fair agreement with the numbers quoted in the TDR

The temperature margin is confirmed



New Temperature Maps



New Temperature Maps



Tuesday, March 9, 2010

Conclusions



Conclusions		
 No conflicts in the constitution DIRC compatibility Doors operation 	urrent design	
GSL 8 Dec. 2000 (Holiday)	Stancelle	10

44
Conclusions
 No conflicts in the current design DIRC compatibility Doors operation Cool-down scenarios have been investigated



				Ι				
	0	n			S	\mathbf{O}	n	S

No conflicts in the current design

- DIRC compatibility
- Doors operation
- Cool-down scenarios have been investigated
- Cable joints losses have been calculated



Conclusions

No conflicts in the current design

- DIRC compatibility
- Doors operation
- Cool-down scenarios have been investigated
- Cable joints losses have been calculated
- New thermal simulations have been performed



Conclusions

No conflicts in the current design

- DIRC compatibility
- Doors operation
- Cool-down scenarios have been investigated
- Cable joints losses have been calculated
- New thermal simulations have been performed

A very preliminary, but quite complete, technical specification for the coil and cryostat tender has been added to the "Interface Document"





Space in the PANDA Hall

- Height of the ceiling on top of the spectrometers
- Cryogenic lines and LHe storage location
- Coil Power supply and quench dump location



Space in the PANDA Hall

- Height of the ceiling on top of the spectrometers
- Cryogenic lines and LHe storage location
- Coil Power supply and quench dump location

 Operations of the coil <u>only</u> in "in beam" position or <u>both</u> in "in beam" and in "garage" position
 Essential to design the supply lines



Space in the PANDA Hall

- Height of the ceiling on top of the spectrometers
- Cryogenic lines and LHe storage location
- Coil Power supply and quench dump location

 Operations of the coil <u>only</u> in "in beam" position or <u>both</u> in "in beam" and in "garage" position
 Essential to design the supply lines

Last but not least, have we a satisfactory design for the cryostat suspension in the flux return yoke?

