Novel internal target source for future storage ring experiments


International Conference on Science and Technology for FAIR in Europe 2014

Nikolaos Petridis

15.10.2014

Target beam generation


- Isentropic expansion of the fluid into vacuum
- The nozzle parameters temperature (T_0) , pressure (p_0) , diameter (d_0) and geometry define the achievable density
- The fluid can be expanded from its gaseous, supercritical or liquid phase, yielding a supersonic jet, cluster or microdroplet beam: multiphase target!
- The target beam is self replenishing




Internal target at the ESR


• The cryostat allows the nozzle operation at temperatures down to $T_0 = 4 K$

• The target density can be derived from the pressure increase in the dump pressure chambers $S_1 - S_4$




Nozzle geometries







Measured cluster target densities




Nozzle geometries







Microdroplet target beam: H₂ area density



Microdroplet target beam: He area density




Helium Droplet Beams at $p_0 = 10$ bar



Electron cooler performance at high densities

 The electron cooler may not be able to compensate the energy loss

 Good agreement between the expected value and the measurement shows no indication of droplet influence




New inlet chamber design

Modular, accessible and compact


 Even higher target densities for all required gases ranging from helium to xenon

Offers smaller target width



Reduced interaction legth

- Modular, accessible and compact
- Even higher target densities for all required gases ranging from helium to xenon
- Offers smaller target width (remotably movable panel and interchangeable skimmers)




New chamber is currently being assembled






Prototype target setup

- Closed cycle cryostat (Sumitomo Refrigerator RDK-415D)
 - > push-button operation
 - ➤ Cooling power of 1.5 W at 4.2 K is sufficient for liquid helium operation
- Target dump chamber
 - ➤ PANDA design (Andrea Bersani, Genova, Italy)



Infrastructure



Summary

- ✓ The technical design report for the new prototype target station was approved and the test setup is currently being assembled at GSI
- ✓ Flexible target operation with exchangeable nozzle geometries
- √ High densities for target species ranging from helium to xenon
- ✓ New, compact inlet chamber design offers further optimization of target properties, e.g. smaller interaction length
- Compact target station can be used at future / current storage rings (ESR, HESR, Cryring, ...)

Acknowledgements

- Th. Stöhlker, M. Steck, R. Grisenti, U. Popp, M. Kühnel, A. Kalinin,
- D. Racano, S. Trotsenko, A. Gumberidze, Yu. Litvinov, G. Weber,
- T. Gassner, D. Winters, S. Hagmann, P.-M. Hillenbrand,
- U. Spillmann, H. Baumgärtel, A. Khoukaz, ...

Thank you for your attention ...!